

LOCAL LIMITS

	PARAMETER	MAXIMUM CONCENTRATION PPM (mg/L)
1	ARSENIC (TOTAL)	0.008
2	ALUMINUM (TOTAL)	2.19
3	CADMIUM (TOTAL)	0.001
4	CHROMIUM (TOTAL)	0.613
5	COPPER (TOTAL)	0.318
6	MERCURY (TOTAL)	0.08
7	NICKEL (TOTAL)	0.238
8	SELENIUM (TOTAL)	0.055
9	SILVER (TOTAL)	0.002
10	AMMONIA NITROGEN	34.8
11	PHOSPHORUS (TOTAL)	8.97
12	CYANIDE	0.110
13	ZINC	0.255*
14	LEAD	0.0025**
15	BOD	300
16	TSS	420
17	pH	6.0 - 12.0***

***This increase went into effect January 1, 2023**

****This increase went into effect November 12, 2019**

*****The upper limit change went into effect September 15, 2015**